

**GOVERNMENT OF WEST BENGAL
DIRECTORATE OF SCHOOL EDUCATION
BIKASH BHAVAN, 7TH FLOOR
SALT LAKE, KOLKATA-700091**

Memo No.-31-SC/AIS/NOC
AIS/RTE/COMMITT./55/2019

Date: 10-03-2022

From : The Convener & Member, State Level Committee for
Recognition of Private unaided Schools
&
Dy. Director of School Education (AIS), West Bengal

To :
The Secretary/Principal,
XAVIER INTERNATIONAL PUBLIC SCHOOL, Kharida, P.O-Kharagpur, Dist-Paschim Medinipur, PIN-721301, W.B.

Sub : Change of name of school in respect of "WARD MEMORIAL CHURCH SCHOOL", Kharida, P.O-Kharagpur, Dist-Paschim Medinipur, PIN-721301, W.B. to "XAVIER INTERNATIONAL PUBLIC SCHOOL".


Ref. : 1. Memo No.-194-SE(S)/6C-27/2007, Dated-17-03-2015 of the School Education Deptt., W.B.
2. Memo No.-15-SC/AIS/NOC, Dated-10-03-2022 of the Directorate of School Education, W.B.

In reference to the aforementioned subject, WARD MEMORIAL CHURCH SCHOOL, Kharida, P.O-Kharagpur, Dist-Paschim Medinipur, PIN-721301, W.B., an unaided private school which was granted "No Objection Certificate Cum Certificate of Recognition" by the School Education Department vide Memo no. 194-SE(S)/6C-27/2007, Dated-17-03-2015.

The School authority has submitted a prayer for change of name of the school from "WARD MEMORIAL CHURCH SCHOOL" to "XAVIER INTERNATIONAL PUBLIC SCHOOL".

The State Level Committee constituted as per provisions of Rule 10 of West Bengal Right of Children to free & Compulsory Education Rules, 2012 in its meeting dated- 16.02.2022, approved the proposal of the School Authority and henceforth the above mentioned school will be recognized as "XAVIER INTERNATIONAL PUBLIC SCHOOL" instead of "WARD MEMORIAL CHURCH SCHOOL".

All other terms and conditions as stated in the Memo No.-15-SC/AIS/NOC, Dated-10-03-2022 for "No Objection Certificate Cum Certificate of Recognition will remain unchanged.



Convener & Member, State Level Committee for
Recognition of Private unaided Schools
&
Dy. Director of School Education (AIS),
West Bengal

Memo. No.-31-1(2)-SC/AIS/NOC
AIS/RTE/COMMITT./55/2019

Date: 10-03-2022

Copy forwarded for information to the:

1. District Inspector of Schools (SE), Paschim Medinipur.
2. Office Copy.


Manager


Principal
**XAVIER INTERNATIONAL PUBLIC SCHOOL
KHARIDA KHARAGPUR**

ATTESTED

Convener & Member, State Level Committee for
Recognition of Private unaided Schools
&



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Date: 26-02-2022

Memo
no.:WBFES/1688/15/Kol/RB/1245/12(1245/12)

From:

Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: Ward Memorial Church School

Premises No.- Rly Plot No.-837, Kharida, Kharagpur-721 301.

Sub: Renewal of Fire Safety Certificate for occupancy of G+I storied, under group Educational building, in the name and style of "Ward Memorial Church School", at premises no-Rly. Plot no-837, Kharida, P.O.-Kharagpur, Dist-Paschim Medinipore, Pin-721301

This is in reference to your application no. 0125191221500006 dated 09-02-2022 regarding the Renewal of Fire Safety Certificate for occupancy of G+I storied, under group Educational building, in the name and style of "Ward Memorial Church School", at premises no-Rly. Plot no-837, Kharida, P.O.-Kharagpur, Dist-Paschim Medinipore, Pin-721301

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1.The Fire Safety audit and evacuation drill to be conducted at 06 (Six) months interval and to be recorded in the Fire Prevention maintenance register and also a copy shall have to be submitted at local fire station.
- 2.Fire pump & detection system always to be kept in auto mode condition.
- 3.Transformer, electrical and Switch Gears room shall be protected with automatic suppression and detection system conforming I.S. specifications.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191221500006.

Page : 1

Manager

Principal

XAVIER INTERNATIONAL PUBLIC SCHOOL
KHARIDA KHARAGPUR

ATTESTED

Powered By


emSigner

For secure paperless solutions
Please visit www.emsigner.com

4. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
5. Entrances / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
6. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
7. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
8. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
9. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the Building.
10. The employees and security staff shall be conversant with installed fire fighting equipments of the building and to operate in the event of fire and testing.
11. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
12. First Aid fire fighting system shall be provided as per I.S. specifications.
13. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
14. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
15. Periodical flashing of water in the Hydrants and sprinklers Pipe lines shall be made to maintain the efficient working performance of above mentioned system.
16. This Renewal of Fire Safety Certificate is valid for 03 (Three) years and has to be renewed within validity limit from the date of issue of this letter.
17. Every 03 (Three) years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number : 0125191221500006.


Page : 2


Manager


Principal

XAVIER INTERNATIONAL PUBLIC SCHOOL
KHARIDA KHARAGPUR

ATTESTED

Powered By  emSigner For secure paperless solutions
Please visit www.emsigner.com

Signature valid

Digitally signed by SAROJ
KUMAR BANO
Date: 2022.02.26 14:15:54 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services


The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number : 0125191221500006.

Page : 3


Manager

Principal
XAVIER INTERNATIONAL PUBLIC SCHOOL
KHARIDA KHARAGPUR

ATTESTED

Powered By  emSigner For secure paperless solutions
Please visit www.emsigner.com